
Excavation works

More than 30 potentially serious events
related to excavation work occurred within the Company in the last 5 years.



Excavation works



une 202: Location Date Company observed Permit No JE5 ~0 AL POINTS TO BE CHECKED Has the "Safety green light" been carried out? Have all identified underground networks been indicated on site? Is a safe distance maintained from overhead power lines 3 and underground networks (> 1 m - 3ft - if excavation by «aggressive» methods)? Are excavators on stable ground with nobody 4 in the working radius of the machine? Have protections against cave-in been installed 5 before personnel enter the excavation? Is the excavation footprint marked out (solid barriers 6 if risk of people or vehicles falling)? Is a safe distance of at least 1 m - 3 ft -, from the edge of the excavation kept free of excavation spoil, machinery or equipment? Before personnel entry, has a safe means of entering 8 and exiting the excavation (stairs, graded slopes or ladders) been installed? Has an inspection of the excavation been carried out 9 before personnel enter? If the atmosphere is potentially hazardous, has a gas test been performed prior to work or to entering 10 the excavation? For the next two cases, use the listed check-list: 11 If confined space, "Confined spaces" check-list If working at height - elevation > 1.5 m (5 ft) - "Work at 12 height" check-list If persons are entering the excavation where the excavation is > 1.3 m (4 ft), or if the excavator 13 operator does not have clear visibility or is working close to underground networks, is a supervisor present? Compliance rate (Nb YES/applicable points): %) 1 (Comments Name Company

Signature